

DRG.
NO.

MBDZ 608

SHEET

1

NEXT SH.

-

TITLE WIRING DIAGRAM SKD & SKE

CONTACT
ARRANGEMENT

SELF RESET

PT No	N/O	N/C
1	A & B	-
2	B	A


NOTE:

1. FOR 110V AC CONNECT ACROSS TERMINALS 5 & 7 AND 8 & 10
2. FOR 0.5V AC CONNECT ACROSS TERMINALS 5 & 8 AND 8 & 9
3. WHEN 2-10 SECS (SKD) DELAY (L.F. FREQUENCY CHECK FEATURES REQD. TERMINALS 11 & 12 ARE TO BE LINKED TO EITHER FOR SKE AS PER SKD BUT TIME DELAY I.e. 0.5-3 SECS.
4. TERMINALS 5,6 AND 8,9 CAN BE EITHER INCOMING OR RUNNING SUPPLIES TAKEN FROM SAME PHASE

SEE NOTE 3



EXT. RESISTOR

COMMERCIAL
COPY

FINISH :-

NEXT STAGE

DATE	BY	CHKD	APPD	REVISION	REMARKS	SCALE	DRAWN	TRACED	CHECKED
20	01	09	01	01	01	01	01	01	01
01	01	01	01	01	01	01	01	01	01
01	01	01	01	01	01	01	01	01	01

ORIGINAL SIZE A4 210 X 297